



भांडागारण विकास और विनियामक प्राधिकरण  
भारत सरकार



एनसीयूआईभवन, चौथी मंज़िल, 3, सीरी इंस्टीट्यूश्रल एरिया, अगस्त क्रान्ति मार्ग,  
हौज़ खास, नई दिल्ली - 110016, दूरभाष - :49536496, 49092978

Warehousing Development and Regulatory Authority  
Government of India

NCUI Building, 4th Floor, 3, Siri Institutional Area, August Kranti Marg,  
Hauz Khas, New Delhi - 110016, Tel. No. 49536496, 49092978

F.No.: WDRA-PD0WR/3/2023-Technical/2276

Date: 20.12.2023

**Amendment to Guidelines dated 28<sup>th</sup> Feb, 2022 on empanelment of inspection agencies and inspection of warehouses**

As per resolution passed in 55<sup>th</sup> Authority meeting, guidelines for inspection of cold storages is amended as under:-

Rule No.	Current Provision	Modified Provision
Schedule 6, Point III.2(vii) – Page : 47	<p><b>Storage Worthiness of Cold Storage:</b> Storage worthiness of the cold storage shall be certified by concerned agency as given hereunder:</p> <p>(a) If it is constructed under Government schemes of NHM / HMNEH / MIDH / NHB / APEDA / MoFPI / NCCD etc. applicant may submit a copy of basic data sheet in prescribed format, duly approved by scheme implementing agency along with a copy of Joint Inspection Report prepared before release of subsidy under the scheme.</p> <p>(b) In case the warehouses (cold storage) has not been set up under the above programmes, the applicant must submit basic data sheet as per format given at Annexure V which should be accompanied by a</p>	<p><b>Storage Worthiness of Cold Storage:</b> Storage worthiness of the cold storage shall be certified by concerned agency as given hereunder:</p> <p>The applicant must submit basic data sheet as per format given at Annexure V which should be accompanied by a certificate from a chartered graduate mechanical / refrigeration engineering firm that –</p> <p>“the heat load calculation has been done as per procedure laid down by ASHRAE fundamentals and Refrigeration Handbook with safety factor of 5% to 10% on estimated load and that the design is energy efficient, takes in to account safety of work men and goods stored and environmental concern”</p> <p><i>No other documents will be required.</i></p> <p>The above condition is applicable for cold storages constructed either under a government scheme or through own finance.</p>

	<p>certificate from a chartered graduate mechanical / refrigeration engineering firm that –</p> <p>“the heat load calculation has been done as per procedure laid down by ASHRAE fundamentals and Refrigeration Handbook with safety factor of 5% to 10% on estimated load and that the design is energy efficient, takes in to account safety of work men and goods stored and environmental concern.”</p>	
--	---	--

नवनीत संधू  
20/11/23

नवनीत संधू  
उप निदेशक (प्रशासन एवं वित्त एवं संविदा)